

# Acidification Protocol for Compliance with the Surface Water Treatment Rule at the Bloomington, IL Water Treatment Plant

**Dr. John T. O'Connor, PE**

**H<sub>2</sub>O'C**  
**ENGINEERING**

# Objective

To scientifically establish a protocol for the acidification of turbidity samples to eliminate interferences from particles formed during lime softening



# IESWTR

40 CFR Parts 9, 141, and 142

National Primary Drinking Water Regulations: Interim Enhanced  
Surface Water Treatment; Final Rule  
Sec. 141.173 Filtration.

(3) A system that uses lime softening may acidify representative samples prior to analysis using a protocol approved by the State.

Systems that use lime softening may apply to the State for alternative exceedance levels for the levels specified in paragraphs (b)(1) through (4) of this section if they can demonstrate that higher turbidity levels in individual filters are due to lime carryover only and not due to degraded filter performance.



# **Bloomington Water Treatment Plant**

## **Lake Bloomington**


































# **Treatment Processes**



<b>Coagulation</b>	<b>Ferric Sulfate, Polymers</b>
<b>Sedimentation</b>	<b>Upflow Contact Clarifiers</b>
<b>Lime Softening</b>	<b>Calcium Carbonate + Magnesium Hydroxide</b>
<b>Recarbonation</b>	
<b>Filtration</b>	<b>GAC-Capped Sand Filters</b>






# Lime Precipitation

Calcium Carbonate + Magnesium Hydroxide

Lake  
Bloomington





































**Filtered  
Overfeed after  
CO<sub>2</sub> Addition  
(pH 9.5)**



# Granular Activated Carbon in Totes







**Sample Tap Opened**

0.86	Total Flow Today
0	Ramp Time Rem
	Surface Wash Fl
0.000	Back Wash Flow

**0.00 Turbidity (NTU)**



FILTER 1

FILTER 3

FILTER 5

FILTER 7

FILTER 9


FILTER 2

FILTER 4

FILTER 6

FILTER 8

FILTER 10



FX Startup

NetView - C:\acctol\c...

FX DDE Server

Microsoft Excel - S...

# Filter Number 14

1/8/02 8:54:09 PM

Filter in Auto  
Backwash Required  
Backwash on Hold  
Normal Level  
Trough Level  
Backwash Emergency Stop  
Controller Fail  
Backwash Watchdog Alarm  
High Loss of Head Alarm  
High Turbidity Alarm

START  
STOP


OPEN	CLOSED	ALARM		
<input type="checkbox"/>	<input checked="" type="checkbox"/>	L <input type="checkbox"/>	R <input type="checkbox"/>	Backwash
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Drain
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Effluent
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Influent
<input type="checkbox"/>	<input checked="" type="checkbox"/>	L <input type="checkbox"/>	R <input type="checkbox"/>	Surface Wash
<input type="checkbox"/> Right Side Inputs				

0.0	Loss of Head (FEET)	Hours In Service Since Last Backwash 13.5
1.39	Total Flow Yesterday (MGD)	
0.82	Total Flow Today (MGD)	
0	Ramp Time Remaining (SEC.)	
	Surface Wash Flow Rate (MGD)	
0.000	Back Wash Flow Rate (MGD)	

Sample Tap Closed

0.28 Turbidity (NTU)

0.92 Flow Rate (MGD)




- |         |         |         |         |          |          |          |          |          |
|---------|---------|---------|---------|----------|----------|----------|----------|----------|
| FILTER1 | FILTER3 | FILTER5 | FILTER7 | FILTER9  | FILTER11 | FILTER13 | FILTER15 | FILTER17 |
| FILTER2 | FILTER4 | FILTER6 | FILTER8 | FILTER10 | FILTER12 | FILTER14 | FILTER16 | FILTER18 |



# Effect of Acidification

## Sludge Blanket Samples


- high initial turbidity
- progressive addition of 1:1 HCl



# Effect of Acidification

## Filter Influent

- low initial turbidity
- four-liter sample
- addition of 1:1 HCl








# MetOne Particle Counter






# Particle Counts

Clarifier  
Effluent




# Particle Counts

Clarifier  
Effluent











**pH 9.7**






**pH 9.0**






**pH 7.5**






**pH 6.8**






**pH 6.3**






**pH 5.4**






**pH 4.7**





**pH 4.1**




**pH 3.1**







**pH 2.5**












**Lake Organisms Cultured in TSB Nutrient Medium  
(cloudy flasks contain concentrated bacteria)**



# Bacterial Cultures at Varying pH

**pH 6.7**

A micrograph showing a dense population of bacterial cells. The cells are small, rod-shaped, and appear to be in various stages of division or movement. The background is a light, grainy texture. A blue horizontal bar at the bottom of the image contains the text "pH 6.7".

# Bloomington's Acidification Protocol

1. Add two drops (0.1 ml) of 1:1 (6N) HCl to a 40 ml sample.

This will result in a pH of approximately 2.

2. Invert several times to mix thoroughly.
3. Wait two minutes or until turbidity is steady-state.





# Basics of Turbidity Measurement

Make sure the turbidimeter is properly calibrated with appropriate standards.

Eliminate factors that would affect the measurement of turbidity:

- condensation
- flocculation
- sedimentation
- air bubbles

Report turbidity readings as follows:


**TURBIDITY RANGE, ntu      REPORT TO NEAREST**

0 - 1.0

0.05

1 - 10

0.1



# Effect of Acidification

**In the Bloomington experiments, the dissolution of lime-softening precipitates by acidification to pH 2 reduced turbidity values by 60 to 87%.**

**Only 13 to 40% of finished water turbidity was due to particles other than calcium carbonate.**

**H<sub>2</sub>O'C**



# **Acidification of Turbidity Samples**

**Utilities practicing lime softening may acidify water samples to redissolve calcium carbonate prior to turbidity measurement.**

**This allows turbidity measurements to be made, primarily, of those classes of particles that were initially in the source water rather than those that were formed as a by-product of the softening process.**

**H<sub>2</sub>O'C**

# Alternate Exceedance Levels

**In the Bloomington experiments, the dissolution of lime-softening precipitates by acidification to pH 2 reduced turbidity values by 60 to 87%.**

**Only 13 to 40% of finished water turbidity was due to particles other than calcium carbonate.**

**Therefore, in the absence of acidification of the finished water samples, alternate exceedance levels of 2 to 4 times the standard exceedance levels would appear to be appropriate.**

**H<sub>2</sub>O'C**



**Dr. John T. O'Connor, PE**

**H<sub>2</sub>O'C Engineering 2401 Tahoe Court Columbia, MO 65203-1444 [www.h2oc.com](http://www.h2oc.com)**

**877-22-WATER**

**573-446-5595**

**[john@h2oc.com](mailto:john@h2oc.com)**

**H<sub>2</sub>O'C**  
**ENGINEERING**